



GUY MASON REC LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	GUY MASON REC	5/20/2016	WS- 012540	Utility	Ground Floor	Exterior, spigot closest to water meter (water source)	WT-042916-12557- A	< 2	WT-042916-12557- B	< 2				
2	GUY MASON REC	5/20/2016	WS- 012541	Cooler	Basement	In hallway across from boiler room High	WT-042916-12558- A	< 2	WT-042916-12558- B	< 2				
3	GUY MASON REC	5/20/2016	WS- 012542	Cooler	Basement	In hallway across from boiler room Low	WT-042916-12559- A	< 2	WT-042916-12559- B	< 2				
4	GUY MASON REC	5/20/2016	WS- 012543	Classroom	Basement	In studio A Right	WT-042916-12560- A	< 2	WT-042916-12560- B	< 2				
5	GUY MASON REC	5/20/2016	WS- 012544	Classroom	Basement	In studio B Left	WT-042916-12561- A	< 2	WT-042916-12561- B	< 2				
6	GUY MASON REC	5/20/2016	WS- 012545	Classroom	Basement	In studio B Right	WT-042916-12562- A	< 2	WT-042916-12562- B	< 2				
7	GUY MASON REC	5/20/2016	WS- 012546	Classroom	Basement	In studio A Left	WT-042916-12563- A	< 2	WT-042916-12563- B	< 2				
8	GUY MASON REC	5/20/2016	WS- 012547	Classroom	1	In activity room1A	WT-042916-12564- A	< 2	WT-042916-12564- B	< 2				
9	GUY MASON REC	5/20/2016	WS- 012548	Kitchen	2	In activity room 2A in kitchen	WT-042916-12565- A	< 2	WT-042916-12565- B	< 2				
10	GUY MASON REC	5/20/2016	WS- 012549	Cooler	2	In hallway across from activity room 2A High	WT-042916-12566- A	< 2	WT-042916-12566- B	< 2				
11	GUY MASON REC	5/20/2016	WS- 012550	Cooler	2	In hallway across from activity room 2A Low	WT-042916-12567- A	< 2	WT-042916-12567- B	< 2				
12	GUY MASON REC	5/20/2016	WS- 012551	Cooler	Ground Floor	Exterior, across from rec center building High	WT-042916-12568- A	< 2	WT-042916-12568- B	< 2				
13	GUY MASON REC	5/20/2016	WS- 012552	Cooler	Ground Floor	Exterior, across from rec center building Low	WT-042916-12569- A	< 2	WT-042916-12569- B	< 2				
14	GUY MASON REC	5/20/2016	WS- 012553	Cooler	Ground Floor	Exterior, across from rec center building (bottom) Low	WT-042916-12570- A	< 2	WT-042916-12570- B	< 2				
15	GUY MASON REC	5/20/2016	WS- 012554	Fountain	Ground Floor	Exterior, adjacent to basketball court Low	WT-042916-12571- A	< 2	WT-042916-12571- B	< 2				
16	GUY MASON REC	5/20/2016	WS- 012555	Fountain	Ground Floor	Exterior, adjacent to basketball court High	WT-042916-12572- A	< 2	WT-042916-12572- B	< 2				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.